



TYPICAL WATERMAIN TRENCH

NOT TO SCALE

NOTES:

- FOR WATER SERVICES, INSTALL IMPORTED PIPE BEDDING A MINIMUM OF 3" THICK ON ALL SIDES OF PIPE.
- MECHANICAL TAMPING AND COMPACTION REQUIRED AS DIRECTED BY THE CITY. WATER SETTLING MAY ONLY BE USED OUTSIDE THE ROADWAY PRISM WHEN APPROVED BY THE CITY.
- ONLY THE LATEST DETAIL, AS APPROVED BY THE DIRECTOR OF PUBLIC WORKS, SHALL BE USED.

Revision	Date	Description	Appr
REV.	6/14	SAWCUT UPDATE	
REV.	01/12	DELETED PVC OPTION	
ORIG.	11/06		

CITY OF SELAH—STANDARD DETAIL

WATERMAIN TRENCH

W-1